

# 2018 Water Quality Report for The Hidden Hamlet Association

This report covers the drinking water quality for Hidden Hamlet Association for the 2018 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2018. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.


Your water comes from three groundwater wells, each over 250 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is low to moderately low.

There are no significant sources of contamination include in our water supply. We are making efforts to protect our sources by following the source water protection guide.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As

water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

- Contaminants that may be present in source water include:
  - **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
  - **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
  - **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
  - **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
  - **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and



septic systems.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2018 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2018. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

**Terms and abbreviations used below:**

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): means the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- N/A: Not applicable ND: not detectable at testing limit ppb: parts per billion or micrograms per liter ppm: parts per million or milligrams per liter pCi/l: picocuries per liter (a measure of radioactivity).
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Regulated Contaminant	MCL	MCLG	Level Detected	Range	Year Sampled	Violation Yes / No	Typical Source of Contaminant
Barium (ppm)	2	2	0.02	NA	2014	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Selenium (ppm)	100	100	0.001	NA	2014	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	<0.1	NA	2018	No	Erosion of natural deposits. Discharge from fertilizer and aluminum factories.
Nitrate	10	10	0.42	0.35-0.42	2018	No	Fertilizers, animal wastes, human wastes, septic systems
TTHM - Total Trihalomethanes (ppb)	80	N/A	12.6	NA	2016	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	2	NA	2016	No	Byproduct of drinking water disinfection
Chlorine* (ppm)	<b>MRDL</b>	<b>MRDLG</b>	0.2	0.1-0.7	2018	No	Water additive used to control microbes
	4	4					
Radioactive Contaminant	MCL	MCLG	Level Detected	Range	Year Sampled	Violation Yes / No	Typical Source of Contaminant
Alpha emitters (pCi/L)	15	0	1.4	NA	2013	No	Erosion of natural deposits
Combined radium (pCi/L)	5	0	0.32	NA	2013	No	Erosion of natural deposits

<sup>1</sup>\*The chlorine "Level Detected" was calculated using a running annual average.

Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water <sup>1</sup>	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	4	ND-5	2016	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.07	ND-0.14	2016	0	Corrosion of household plumbing systems; Erosion of natural deposits

Unregulated Contaminant Name	Average Level Detected	Range	Year Sampled	Comments
Chloride ppm	2.98	2.22-2.98	2018	Typical source is erosion of natural deposits
Sodium ppm	<5.0	NA	2018	Typical source is erosion of natural deposits
PFOA	ND	NA	2018	Chemicals that are resistant to heat, water, and oil used in industrial applications and consumer products such as carpeting, waterproof clothing, upholstery, food paper wrappings, fire-fighting foams, and metal plating.
PFOS	ND	NA	2018	Chemicals that are resistant to heat, water, and oil used in industrial applications and consumer products such as carpeting, waterproof clothing, upholstery, food paper wrappings, fire-fighting foams, and metal plating.

<sup>1</sup> Ninety (90) percent of the samples collected were at or below the level reported for our water.

**Information about lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hidden Hamlet is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**From January 1, 2018, to December 31, 2018:**

Microbial Contaminants	MCL	MCLG	Number Detected	Violation Yes / No	Typical Source of Contaminant
Total Coliform Bacteria	>1 positive monthly sample (>5.0% of monthly samples positive)	0	0	No	Naturally present in the environment
Fecal Coliform and <i>E. coli</i>	Routine and repeat sample total coliform positive, and one is also fecal or <i>E. coli</i> positive	0	0	No	Human and animal fecal waste

Monitoring and Reporting to the DEQ Requirements: The State and EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2018.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the well house on Sun Valley Drive or by contacting Tammi Gall @ 740-403-4519 or [tammi.gall@meadhunt.com](mailto:tammi.gall@meadhunt.com). This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. For more information about your water, or the contents of this report, contact Tammi Gall @ 740-403-4519 or [tammi.gall@meadhunt.com](mailto:tammi.gall@meadhunt.com). For more information about safe drinking water, visit the U.S. Environmental Protection Agency at [www.epa.gov/safewater/](http://www.epa.gov/safewater/).