

2023 Water Quality Report for Hidden Hamlet Association

Water Supply Serial Number: 03132

This report covers the drinking water quality for Hidden Hamlet Association for the 2023 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2023. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from 3 groundwater wells, each over 250 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is low to moderately low.

There are no significant sources of contamination in our water supply. We are making efforts to protect our sources by participation in the wellhead protection program.

If you would like to know more about this report, please contact: Tammi Gall, Mead & Hunt, 231-333-6874, tammi.gall@meadhunt.com.


Contaminants and their presence in water: Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **U.S. EPA's Safe Drinking Water Hotline (800-426-4791)**.

Vulnerability of sub-populations: Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the **Safe Drinking Water Hotline (800-426-4791)**.

Sources of drinking water: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.



To ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2023 calendar year. The presence of a contaminant in drinking water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is representative of the water sampled from January 1 through December 31, 2023. The State allows us to monitor for certain contaminants less than once per year. The concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water sampled less than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for the use of advanced treatment technology.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not apply to the use of disinfectants to control microbial contaminants.
- **Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.
- **Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppm:** parts per million or milligrams per liter **ppb:** parts per billion or micrograms per liter **ppt:** parts per thousand

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Nitrate (ppm)	10	10	0.68	NA	2023	No	Runoff from fertilizers, septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	<0.1	NA	2023	No	Erosion of natural deposits which promotes strontium, fertilizer and aluminum
Sodium ¹ (ppm)	N/A	N/A	<5	NA	2023	No	Erosion of natural deposits
TTHM Total Trihalomethanes (ppb)	80	N/A	8.1	NA	2022	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	ND	NA	2023	No	Byproduct of drinking water disinfection
Combined radium (pCi/L)	5	0	0.090	N/A	2022	No	Erosion of natural deposits
Alpha emitters (pCi/L)	15	0	ND	N/A	2022	No	Erosion of natural deposits

¹Sodium is not a regulated contaminant.

Per- and polyfluoroalkyl substances (PFAS)							
Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of C
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ppt)	370	N/A	ND	NA	2023	No	Discharge and was utilizing the Gen X
Perfluorobutane sulfonic acid (PFBS) (ppt)	420	N/A	ND	NA	2023	No	Discharge and was facilities; stain-resis
Perfluorohexane sulfonic acid (PFHxS) (ppt)	51	N/A	ND	NA	2023	No	Firefighting foam; d from industrial facilit
Perfluorohexanoic acid (PFHxA) (ppt)	400,000	N/A	ND	NA	2023	No	Firefighting foam; d from industrial facilit
Perfluorononanoic acid (PFNA) (ppt)	6	N/A	ND	NA	2023	No	Discharge and was facilities; breakdow
Perfluorooctane sulfonic acid (PFOS) (ppt)	16	N/A	ND	NA	2023	No	Firefighting foam; d facilities; discharge from industrial facilit
Perfluorooctanoic acid (PFOA) (ppt)	8	N/A	ND	NA	2023	No	Discharge and was facilities; stain-resis
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water ¹	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of
Lead (ppb)	15	0	3.3	0-12	Jan-June 2023	0	Lead service lines plumbing including of natural deposits
Copper (ppm)	1.3	1.3	0.11	0-0.18	Jan-June 2023	0	Corrosion of house Erosion of natural
Lead (ppb)	15	0	55	0-85	July-Dec 2023	2	Lead service lines plumbing including of natural deposits
Copper (ppm)	1.3	1.3	0.3	0.1-0.5	July-Dec 2023	0	Corrosion of house Erosion of natural

³ Ninety (90) percent of the samples collected were at or below the level reported for our water

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hidden Hamlet Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Infants and children who drink water containing lead could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

The monitoring period July 2023 to December 2023 there were 2 lead samples above the action level. Hidden Hamlet followed EGLE requirements and let the residents know and offered additional sampling for lead and copper to homeowners whom wanted their water tested. The 2 samples that exceeded the action level were retested and results came back below the action level, the 2 sites were investigated with no source of lead found. Hidden Hamlet also sent out a home survey to help gather information of plumbing in homes to ensure no lead sources were found. Hidden Hamlet will continue to test for lead and copper per EGLE requirements.

Monitoring and Reporting to the Department of Environment, Great Lakes, and Energy (EGLE) Requirements: The State of Michigan and the U.S. EPA require us to test our water on a regular basis to ensure its safety. We met all the monitoring and reporting requirements for 2023.

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the well house or by contacting Tammi Gall, Mead & Hunt, 231-333-6874, tammi.gall@meadhunt.com.

We invite public participation in decisions that affect drinking water quality.

For more information about your water, or the contents of this report, Tammi Gall, Mead & Hunt, 231-333-6874, tammi.gall@meadhunt.com. For more information about safe drinking water, visit the U.S. EPA at <http://www.epa.gov/safewater>.